



LAS VEGAS FIRE & RESCUE

FIRE PREVENTION DIVISION

Additional Emergency Access

The intent of this regulation is to clarify the secondary emergency access requirements as indicated with the adopted Fire Code Section 503.1.2 Additional Access.

Regulation

The *fire code official* is authorized to require more than one fire apparatus access road based on the potential for impairment of a single road by vehicle congestion, condition of terrain, climatic conditions or other factors that could limit access.

Approved secondary access shall be provided for 200 or more dwelling units, road(s) with dead ends or with a single point access in excess of 600 feet (182 880 mm).