



Las Vegas Fire & Rescue Fire Prevention Division Information Sheet



Effective Date: July 1 2014

CLV Ordinance #6325

The items listed are basic information only. Codes are subject to change. Additional requirements may apply.

Fire Extinguisher Inspection Requirements

Fire extinguishers shall be manually inspected at a minimum of a 30 day interval. **NFPA 10 7.2.1.2**

All portable fire extinguishers except the carbon dioxide extinguishers, disposable extinguishers and Halon extinguishers must be recharged at least annually and whenever the service seal has been broken or an inspection indicates that the extinguisher might fail to function.

NAC 477.030 & NFPA 10 7.3.1.1.1

Fire extinguishers shall be inspected annually by a company properly licensed by the Nevada State Fire Marshall. The company representative performing the servicing shall attach a label to the extinguisher at the conclusion of the servicing. The label shall comply with the following:

1. be attached to the extinguisher by wire, string or a plastic tie; or
2. be a self-adhesive tag approved by the State Fire Marshal which is so attached as to be readily visible for inspection. **NAC 477.425**

A licensee shall replace extinguishers removed from premises for servicing with spare extinguishers of equal or higher ratings during the period the extinguishers being serviced are removed. Failure to comply with the provisions of this section is a ground for the immediate suspension or revocation of the certificate of registration of the licensee. **NAC 477.420 & NFPA 10 7.1.3**

A licensee shall respond to a call for service from a customer, the State Fire Marshal or the authority having jurisdiction within 24 hours with proper equipment to repair or replace the fire protection equipment. If unable to respond, the licensee shall communicate with another licensee who is able to respond and repair or replace the equipment. **NAC 477.422**

Las Vegas Fire & Rescue
Fire Prevention Division
(702)229-0366
www.lasvegasnevada.gov/LawsCodes/fire_code.asp